

REINHOLD ENVIRONMENTAL[®]



2026 Reinhold/PCUG Round Table Presentation

Hosted by TVA, Southern Company and Vistra
in the Sonesta Nashville Airport Hotel, Nashville, TN
on June 22-23, 2026

All presentations posted on this website are copyrighted by **REINHOLD ENVIRONMENTAL[®]** (RE). Any unauthorized attempts to print, to download, to modify, to incorporate into other presentations, to link to other websites or to obtain copies for any other uses than the training of attendees to RE Conferences is expressly prohibited unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials in this library which were presented and/or created by persons who were not employees or subcontractors of RE.



Managing SCR Systems through Plant End-of-Life or Natural Gas Conversion



Jared Koliha – CERAM (presenting author)
Maggie Skelton - Minnesota Power
Noel Rosha – CERAM

June 22, 2026

Introduction

Coal-fired power plants facing end-of-life or natural gas conversion must ensure SCR performance is maintained while limiting risk and capital and O&M expenditures throughout the transition. Proper SCR system analysis and collaboration with plant personnel are crucial to achieve these goals. This presentation will explore details of a real-life case example of a plant working through this transition.

- Presentation Road Map
 - Background
 - Case-Study Minnesota Power Boswell Unit 3




Background


Unique aspects of short-term catalyst management optimization

- Simplifying solutions
- Emphasis on balancing capital and O&M spend
- Identifying operational 'knobs-to-turn'
- Scenario management becomes critical
 - Plans change frequently
- Accurately defining performance and system requirements provides the most bang-for-buck
 - Knowing which way to turn starts with knowing where you are

"Map out your future- but do it in pencil. The road ahead is as long as you make it."- Jon Bon Jovi



Case Study- Minnesota Power Boswell Unit 3



Boswell Unit 3


Operations

- 364 MW, T-fired, PRB
- SCR commercial operation in 2010 as 3+1, single reactor
- Historical SCR pluggage problems
- Originally 5.7 mm, 2 x 625 mm plate catalyst
- Began working with CERAM on a limited basis in 2014
- Changing combustion, deactivation, operating targets

Plans

- 2029 EOY refuel or coal-to-gas conversion
- Reduce capital costs
- Provide flexibility in catalyst management planning for potential coal-to-gas conversion
 - Gas-fired operating conditions yet to be determined

Defining Operational Goals




Roadblocks in Planning

Operational changes

- Changes in fuels and combustion
 - Increasing SCR temperatures (750°F to >800°F), etc.
- Continued deterioration of existing LPA screen
 - Increasing catalyst pluggage


“Detours”

- Increasing slip
 - Eliminating one catalyst event
 - Three-layer operation instead of four-layer
 - dP concern with four layers



Corrective action needed to maintain NOx reduction goals!

Pressure Drop Concerns



Recalculating...

What is the best means of course correction with a shortened timeline?

- Avoiding tolls - limiting O&M impact
- Avoiding construction – limiting capital impact
- Identifying cost-effective solutions to both
- Discussions/lessons from this case study applicable to EOL analysis

Cost Effective Course Correction

Fixing root causes

- LPA screen replacement (*Fall 2022*)
 - O&M (dP) and capital (catalyst) benefits
 - LPA carryover through economizer bypass (no LPA screen)
- Combustion control improvements
 - Improve firing uniformity
- Installing a fourth layer
- AIG Check
 - Ensuring $\text{NH}_3:\text{NO}_x$ distribution and DeNO_x reaction has best chance for success




Addressing symptoms

- Extensive outage cleaning (*Fall 2022*)
- Accurately identifying limiting operating cases (DeNO_x demand)
- Manage catalyst decisions to available surface area and deactivation rates
- Optimizing catalyst geometry for high residual pluggage and LPA carryover
- Install fourth catalyst layer



Combustion Improvements




Identifying Limiting Operating Case

- Mining DCS data to determine realistic high load cases (high DeNOx demand)
 - Recognize applicable statistics and any shortcomings in available data
- Identify appropriate ammonia slip targets

Boswell Unit 3 Operations Basis		
Parameter	Original Design Basis	Most Recent Model Basis Case Load >350 MW Sept-Dec 2025 Data
Inlet NOx, lb/MMBtu	0.5	0.204 ⁽¹⁾
Outlet NOx, lb/MMBtu	0.05	0.054
Ammonia Slip, ppmvdc	2	< 5-7 ⁽²⁾
Fuel Burn Rate, MMBtu/hr	3,517	3,523 ⁽³⁾
Flue Gas Temperature, °F	760	790 ⁽⁴⁾
Gas Flow Rate, acfm	1,843,000	2,014,300
Notes: (1) Average full load plus two standard deviations from 2025 DCS data. (2) Estimated ammonia slip considering operating data and expected catalyst pluggage. Correcting from current to 5 ppm. (3) Average full load plus one standard deviation from 2025 DCS data. (4) The average temperature at full load is 790 °F with a maximum measured of 821 °F (+1 standard deviation is 800 °F).		


Addressing Catalyst Pluggage

- Replacement of LPA screen
- Aggressive outage cleaning
- Addressing existing/legacy pluggage
 - Previously plugged upper layers impacting layers below
 - Ash sweeper maintenance and operation
- Eliminating sublayer pluggage, increase pitch



Single Sublayer

- Cleaning Energy Reaches Top to Bottom
- Eliminates Sublayer Pluggage
- Easier to Pass Large Particle Ash (LPA)
- Lowest Pluggage and Minimal Long Term Pressure Drop




Gap Between
Sublayers


Two Sublayer
Design

- Cleaning Energy Dissipates in Gap
- LPA Can Lodge in Sublayer
- Pluggage Potentially Builds in Sublayer
- More Susceptible to Non-Uniform Flow Conditions


Catalyst Management Strategy



Catalyst Management Strategy




Catalyst Management Strategy- 7.0mm, 1 x 1,000mm




The Two Layer, 7.0mm, 1x1,000mm Approach

- Addresses dP problem
 - Cycles through heavily plugged layers
- Meets the outage schedule*
- Facilitates two decision points
 - Spring 2028
 - One or two layers to EOY 2029
 - Smaller pitch or longer length?
 - Fall 2029
 - Will targets change?
 - Additional clarity on NG conversion




The Two Layer, 7.0mm, 1x1,000mm dP






Current

- Four layers of shorter catalyst, larger pitch
 - dP improvements and gains in RP



Previous

Spring 2028 Decision Point



2030 Gas-Conversion


- Design details aren't available; hypothetical case presented
 - 30% lower inlet NO_x
 - Maintain outlet NO_x
 - Stabilize slip at 5 ppm
 - SCR inlet temp reduced by 50°F
 - Heat input approximated



Boswell Unit 3 Operations Basis		
Parameter	Most Recent Model Basis Case Load >350 MW Sept-Dec 2025 Data	Example NG Operating Case (Values Estimated)
Inlet NO _x , ppmvdc	150	105
Outlet NO _x , ppmvdc	40	40
Ammonia Slip, ppmvdc	< 5-7	5
Fuel Burn Rate, MMBtu/hr	3,523	3600
Flue Gas Temperature, °F	790	740
Gas Flow Rate, acfm	2,014,300	1,758,032

Natural Gas Conversion: Effects on Existing Catalyst

- Catalyst designed for coal relies on SO₂ in the flue gas to promote DeNO_x
 - In NG stream without SO₂, catalyst activity will be reduced (reduced reactor potential)
 - NG catalyst generally has more active metals
- CERAM recommends testing used catalyst as-received with SO₂ and after catalyst is conditioned to no SO₂ environment
 - Condition in hot, SO₂ free flue gas to drive off residual SO₂
 - Perform repeated catalyst activity tests until activity levels out
 - Perform final catalyst activity test without SO₂ to determine catalyst activity in natural gas flue gas regime




Gas Conversion Best Practice

- Remove all ash
- Re-evaluate DeNOx demand
- Ensure adequacy of whole system
 - Ammonia supply, control, etc.
- Test catalyst at representative NG conditions
 - SO₂ and temperature impacts
- Immediate conversion to smaller pitch may not be necessary
 - Truly small pitch gas catalyst is too fine for residual ash
 - Buffer period to for residual ash to settle




*Perform a system
diagnostic before the
next leg of the journey*

Catalyst Management: Coal-to-Gas Conversion



Catalyst Management: Coal-to-Gas Conversion



Conclusions

- Current strategy corrects issues and sets up next stage of unit operation
 - Four layers of single sublayer, large pitch
 - Addressing pluggage and providing sufficient reactor potential
- Situation still open-ended
 - Gas conversion details/schedule still up in the air
- Other options additionally considered to meet EOY 2029
 - Moving outages
 - Reverting to two sublayer design
 - Derates, etc.
- More aggressive approaches to EOY 2029 will moderate as runtime changes

Questions?



Jared Koliha
Ceram USA, Inc.
Jared.Koliha@ceram-usa.com
913-239-9896