

REINHOLD ENVIRONMENTAL Ltd.



**2018 NO_x-Combustion Round Table
& Expo Presentation**

February 19-20, 2018, in St. Louis, MO / Hosted by Dynegy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendees to RE's Conferences is expressly prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.



Optimizing SCR Catalyst Utilization

Volker Rummenhohl
V-Tack, LLC

2018 NO_x-Combustion-CCR Round Table
St. Louis February 20, 2018

Agenda

- General Topic Overview
 - New power industry situation
- Catalyst exchange strategy
- Importance of Reactor Potential VS Simply Activity Measurements
- Prioritizing Factors Affecting Catalyst Management
- Catalyst Testing and Benchmarking
- Regenerated Catalyst Considerations
- Comparing New and Regenerated Catalyst
 - Evaluation concepts

General Topic Overview




General Topic Overview

- Renewables on fast pace taking over
- XCEL Energy received 400 bids for wind plus storage and solar plus storage
 - Average price for wind plus storage 2.1 cents/kWh
 - Average price for solar plus storage 2.7 cents/kWh
- APS signed a 15-year PPA with First Solar for a 65 MW solar farm and 50 MW, 135 MWh battery
- Apple Campus 2 off the grid




General Topic Overview

Utility-scale capacity additions, 2010-2017
gigawatts



Utility-scale renewable capacity additions
gigawatts



Source: U.S. Energy Information Administration, Form EIA-860M, *Preliminary Monthly Electric Generator Inventory*


General Topic Overview

- Natural gas price remains low
- Former base loaded coal units are now frequently cycling
- Reduced operating hours, but in many cases higher catalyst deactivation




Catalyst Exchange Strategy


Catalyst Exchange




Expectation




On Track



Positive Deviation



Negative Deviation




Impacts on Catalyst Strategy

- Fuel
- Operating conditions
- Ammonia Flow Control System
- Plugging/Erosion/Corrosion(Plate)
- Additives
- Catalyst test conditions
- Catalyst laboratory
- Calculation
- Actual flue gas data VS design data
- Catalyst selection

Catalyst Potential



Catalyst Potential




Critical Catalyst Management Planning Consideration

**If Your Laboratory
Element Looks
Like This...**



**...But Your Operating
Catalyst Looks
Something Like This...**



Things Are Not As Good As You Think!

K Measurement \neq Reactor Potential

Critical Catalyst Management Planning Consideration

**If Your Laboratory
Element Looks
Like This...**



**...But Your Operating
Catalyst Looks
Something Like This...**



Things Are Not As Good As You Think!

K Measurement \neq Reactor Potential



Critical Catalyst Management Planning Consideration

**If Your Laboratory
Element Looks
Like This...**



**...But Your Operating
Catalyst Looks
Something Like This...**



Things Are Not As Good As You Think!

K Measurement \neq Reactor Potential

Catalyst Activity VS Potential



Catalyst Activity VS Potential

- Catalyst Potential

$$P = k/Av$$

- Factors
 - NO_x removal efficiency
 - Ammonia slip
 - Velocity, Temperature and NH₃/NO_x distributions
- The effective catalyst potential must be at all times above the catalyst potential calculated at the end of the catalyst lifetime


Critical Catalyst Management Planning Consideration

To Accurately Assess Reactor Potential

- Annual Catalyst Activity Testing
- Annual Catalyst Mechanical Assessment
 - Pluggage
 - Erosion (Open Holes = Flow Diversion)
 - Mechanical Condition
 - Plate Especially - Consistent Spacing
 - Seal Effectiveness
- Annual Operating Condition Assessment
 - Operated Like Design? (e.g., $\Delta T = \Delta K$)

Catalyst Potential


Figure 1 - Catalyst Management Plan




Flue Gas Distributions

Flue Gas Distributions


**Figure 1. Baseline Outlet NOx Differentials
Stuart Unit 3**



**Figure 2. Final Outlet NOx Differentials
Stuart Unit 3**



Flue Gas Distributions





Flue Gas Distributions

- 815 MW PRB fired boiler
- Original design allowed for extensive ash buildup/plugging in back of reactor which increased velocities elsewhere causing catalyst to erode.
 - Multiple catalyst change outs in five (5) years between 2007 and 2012.
 - Multiple annual shut downs to clean the reactor
- The goal of the project was to design flow distribution devices capable of improving the velocity distribution into the catalyst reactor by 40% from the baseline and eliminate recirculation areas in the reactor hood.



Flue Gas Distributions Original Design



Flue Gas Distributions Baseline CFD Results





High and low spots from the turning vanes are helped by the straightening grid and perforated plate but still yield a poor distribution into the 1st catalyst layer.





Vectors near vanes show recirculation areas where potential ash fallout can occur.

Flue Gas Distributions Final CFD Results



Flow shadows from large truss reduced with new design.



Flow vectors all down, no recirculation

Flue Gas Distributions Final CFD Results



Flue Gas Distributions

- Baseline Catalyst Inlet Velocity Profile – 17.5% RMSE
 - % within +/- 15% of average = 57.9%
 - % within +/- 30% of average = 88.6%
- Final Catalyst Inlet Velocity Profile – 9.4% RMSE
 - % within +/- 15% of average = 90.8%
 - % within +/- 30% of average = 98.8%
- No outages for cleaning between planned outages
- Overall system pressure drop lower (clean condition) compared to original design



Flue Gas Distributions

- 300 MW bituminous coal fired boilers
- Retrofit of Large Particle Ash LPA screen
- Pressure drop increase due to catalyst plugging with LPA and air heater fouling with ABS forced the units to be de rated after ten weeks
- Every boiler had to come every three months down to vacuum the dust of the catalyst.
- Very high catalyst consumption

Flue Gas Distributions

Recommended Design
Average Velocity 61ft/s Max
85 ft/s

Low Angle may lead to ash
deposition



Flue Gas Distributions Statistical Comparison


Summary	Baseline	Recommended Design
LPA Screen velocity (ft./s)		
Min.	17.2	10.5
Max.	101.3	85.3
Average	71.7	61.1
RSME	26.2	20.4

Flue Gas Distributions Results

- No more pressure drop increase
- No catalyst cleaning between scheduled outages
- 2.2 i.w.g. pressure drop improvement


Control System

Ammonia Consumption



Boiler Operation

Operating Data



Accuracy

Round Robin 2012



Auswertung VGB-Ringversuch Benchreaktor 2009 – 2012 Plattenkatalysatorelement

Testbedingungen:

Volumenstrom	150 Nm ³ /h
Temperatur	380 °C
Area Velocity	38,4 Nm/h
$\phi(\text{NO}_x)_{\text{tr}}$	300 ppmv
$\phi(\text{SO}_2)_{\text{tr}}$	500 ppmv
$\phi(\text{O}_2)_{\text{tr}}$	5 vol. %
$\phi(\text{CO}_2)_{\text{tr}}$	ca. 12 vol. %
$\phi(\text{SO}_3)_{\text{tr}}$	0 vol. %
$\phi(\text{H}_2\text{O})$	15 ± 1 vol. %
$\alpha = n(\text{NH}_3) / n(\text{NO}_x)$	1

Round Robin 2012




Einzelwerte der Aktivitätsbestimmung:

Labor	Aktivität K [Nm/h]					
L1	41,8	42,7	42,1	42,2	42,1	42,1
L2	42,8	42,8	42,7	42,9	42,9	
L3	43,4	43,4	43,6	43,9	43,8	43,3
L4	42,4	43,1	42,8	43,0	43,2	
L5	44,5	44,1	44,2	44,3	44,3	
L6	44,1	43,5	44,5	44,4	45,1	
L7	48,2	47,7	47,0	45,4	45,7	45,1
L8	39,5	39,3	39,2	39,0		
L9	41,3	41,1	41,2	41,2	41,2	
L10	42,9	42,8	43,3	42,2	42,8	
L11	46,8	47,0	46,7	46,6	46,7	
L12	48,3	48,3	49,5	48,2	48,5	

Average 43.9 m/h



Round Robin 2012




Participating Laboratories

- BHK
- CERAM
- Cormetech (2)
- DKC (CN)
- E.ON (2)
- EnBW
- Evonik/STEAG (DE)
- Johnson Matthey
- STEAG (US)



Round Robin 2012



Participating Laboratories

- BHK
- CERAM
- Cormetech (2)
- DKC (CN)
- E.ON (2)
- EnBW
- Evonik/STEAG (DE)
- Johnson Matthey
- STEAG (US)




Round Robin 2012



Participating Laboratories

- BHK
- CERAM
- Cormetech (2)
- DKC (CN)
- E.ON (2)
- EnBW
- Evonik/STEAG (DE)
- Johnson Matthey
- STEAG (US)



Round Robin




Einzelwerte der SO₂-Konversionsrate

Labor	Konversionsrate [%]					
L1	0,36	0,31	0,31	0,31	0,36	0,32
L2	0,27	0,30	0,30	0,32	0,30	
L3	0,37	0,45	0,33	0,36	0,36	
L4	0,37	0,36	0,34	0,39	0,35	0,37
L5	0,38	0,38	0,39	0,42	0,39	
L6	0,32	0,25	0,29	0,28	0,29	
L7	0,30	0,28	0,31	0,29	0,28	0,29
L8	0,24	0,25	0,23			
L9	0,26	0,26	0,26	0,26	0,26	
L10	0,46	0,39	0,43	0,47	0,52	0,45
L11	0,37	0,36	0,37	0,36	0,36	
L12	0,42	0,34	0,41	0,41	0,41	

Average 43.9 m/h




Round Robin



Round Robin 2006

VGB Honeycomb Catalyst Round Robin Test Results (2006)



Sample Size

Micro- versus Bench Reactor





Additives





Additives

- Calcium or magnesium injection for ABS prevention
- Addition to the coal, injection in the furnace or before SCR
- Has been proven since the early 90s for SO_3 and arsenic mitigation


Additives




Additives



Additives



Additives




New VS. Regenerated Catalyst




New VS Regenerated Catalyst

- Capital VS lifetime cost
- Deactivation over time
- Catalyst Potential
- History of regenerated catalyst
- Long time cost evaluation



New VS Regenerated Catalyst



New VS Regenerated Catalyst



New Catalyst




Regenerated
Catalyst Type 1



Regenerated
Catalyst Type 2

Catalyst Activity VS Potential



Economic Example

600 MW Coal Plant Catalyst Management Plan

Past History

Future Plan

Past

Future



Case 1 – New Catalyst For All Future Replacements (3 Year Outages)




Three Year Outage Plan Achieved!



Case 1 – New Catalyst For All Future Replacements (3 Year Outages)

Net Present Value Analysis in 2018 Dollars			
Catalyst Related Expenditures			\$ 8,176,000
Residual Catalyst Activity Value Remaining at End of Plan (2032)			\$ (16,000)
Fan Energy Costs for Reactor Pressure Drop			\$ 3,613,000
Total Net Present Value of Plan (2018 to 2032)			\$ 11,773,000
NPV NOx Removal Cost of Plan (2018 to 2032)			121 \$/ton
Analysis Assumptions			
Escalation Rate	4.0%	New Honeycomb Catalyst Cost (2018)	\$4500/m3
Present Worth Discount Rate	10.0%	New Plate Catalyst Cost (2018)	\$3300/m3
Annual SCR Operation, hours/year	6,000	Catalyst Regeneration w/transport (2018)	\$2400/m3
Capacity Factor	70%	Catalyst Removal Cost (2018)	\$800/module
Fan Energy Cost (2018)	\$0.06/kwh	Catalyst Installation Cost (2018)	\$1000/module
		Catalyst Disposal Cost (2018)	\$400/m3



Case 2 – Regenerated Catalyst For All Future Replacements

**Cannot Withstand
Reduced Performance!**



Regen Catalyst Assumptions (vs New):

+5% Pluggage

-10% Activity (equivalent SO₂:3)

+5% Deactivation Rate

No Difference in Mechanical Quality (Realistic?)

Not Possible to Maintain 3 Year Outage Plan!



Case 2 – Regenerated Catalyst Requires More Frequent Replacements

Regen Catalyst Assumptions (vs New):

+5% Pluggage

-10% Activity (equivalent SO₂:3)

+5% Deactivation Rate

No Difference in Mechanical Quality (Realistic?)

**Replacements Required Every Two Years to
Maintain Performance**



Case 2 – Regenerated Catalyst Requires More Frequent Replacements

Net Present Value Analysis in 2018 Dollars			
Catalyst Related Expenditures		\$	7,597,000
Residual Catalyst Activity Value Remaining at End of Plan (2032)		\$	0
Fan Energy Costs for Reactor Pressure Drop		\$	3,782,000
Total Net Present Value of Plan (2018 to 2032)		\$	11,379,000
NPV NOx Removal Cost of Plan (2018 to 2032)			117 \$/ton
Analysis Assumptions			
Escalation Rate	4.0%	New Honeycomb Catalyst Cost (2018)	\$4500/m3
Present Worth Discount Rate	10.0%	New Plate Catalyst Cost (2018)	\$3300/m3
Annual SCR Operation, hours/year	6,000	Catalyst Regeneration w/transport (2018)	\$2400/m3
Capacity Factor	70%	Catalyst Removal Cost (2018)	\$800/module
Fan Energy Cost (2018)	\$0.06/kwh	Catalyst Installation Cost (2018)	\$1000/module
		Catalyst Disposal Cost (2018)	\$400/m3

- Nearly Identical NPV to New Catalyst NPV
- Two Year Outage Interval Required
- 8 Events (Regen Cat) vs 5 Events (New Cat)
- What is Indirect Cost of 2 vs 3 Year Outage Interval?
- Reduced Mechanical Quality vs New = Reduced Interval

+5% Pluggage
 -10% Activity (equivalent SO₂:3)
 +5% Deactivation Rate

Conclusions

- Catalyst activity and conversion rate test results over time must be comparable
- Catalyst lifetime is constantly changing
- Numerous tools are available to extend the catalyst lifetime
 - Boiler operation optimization
 - AIG tuning
 - Improve distributions
- Additives become economical, if other effects are considered
- Advantages of new versus regenerated catalyst depend on the criteria

Thank you very much

Questions?

